

Certificate

No. SEBS-A.134501/16, V1.0

TÜV NORD Systems GmbH & Co. KG hereby certifies to

Yokogawa Electric Corporation
2-9-32 Nakacho, Musashino-shi, Tokyo
180-8750 Japan

that the safety-related

YTA Temperature Transmitter

is capable for safety-related applications up to SIL 2/SIL 3 depending on the architecture and meets the requirements listed in the following standard.


IEC 61508: 2000; Functional safety of electrical/electronic/programmable electronic safety-related systems;
SIL 2 capability for single transmitter use;
SIL 3 capability for dual transmitter use

Base of certification is the report SEBS-A.134501/16TB in the valid version.

This certificate entitles the holder to use the pictured safety approved mark.

Valid until: 2019-04-08
File reference: 8113288588

Hamburg, 2016-04-08



Bianca Pfuff

