

# Certificate

1435.IM.113636/23, V1.0

TÜV NORD Systems GmbH & Co. KG hereby certifies to

**Druck Limited**  
Fir Tree Lane  
Groby, Leicester LE6 0FH  
England

that the pressure transmitter

## PTX435 4-20mA 10k SIL Dual

(derived from drawing 125M3774) is capable for safety related applications and meets the requirements listed in the following standards.

- IEC 61508 part 1, part 2 and part 3: 2010, SIL 2 with HFT = 0 and SIL 3 with HFT > 0

Certification program Leittechnik (SEB-ZE-SEECERT-VA-320-20, Rev. 5.1 / 4.19)

Base of the certification are the report  
1435.IM.113636/23TB in the valid version.  
This certificate entitles the usage of the  
adjacent conformity mark.

Valid until: 2029-03-01  
File reference: 8122284586

Hamburg, 2024-03-01



Bianca Pfuff

Certification Body SEECERT  
TÜV NORD Systems GmbH & Co. KG  
Große Bahnstraße 31, 22525 Hamburg, Germany

