

Certificate

No. SEBS-A.144502/13, V1.0

TÜV NORD Systems GmbH & Co. KG
certifies

Schneider Electric Automation GmbH
Breslauer Straße 7
77933 Lahr,

that the safety function "Safe Torque Off" (STO) of the drive system

Lexium 32

within the variants LXM32XU45M2; LXM32XU90M2; LXM32XD18M2; LXM32XD30M2,
LXM32XU60N4, LXM32XD12N4, LXM32XD18N4, LXM32XD30N4; LXM32XD72N4;
LXM32XD85N4; LXM32XC10N4

is capable for safety applications up to SIL 3, PL e category 3.

The requirements of the following standards are fulfilled.

- IEC 61508 Part 1:2010; Part 2:2010
- IEC 62061:2005
- IEC 61800-5-2:2007
- ISO 13849 Part 1:2006; Part 2:2012

The certification is based on the report
SEBS-A.144502TB1 in the valid version.
This certificate entitles the holder to use
the pictured safety approved mark.

Expire date: 2019-04-01
Reference No.: 8110398211

Augsburg, 2014-04-01


Gerhard M. Rieger

