



Certificate

No. SEBS-A.102618/13 V2.0

TÜV NORD Systems GmbH & Co. KG hereby certifies to

GE Infrastructure Sensing, LCC

1100 Technology Park Drive
Billerica MA 01821-4111 USA

that the ultrasonic flow measurement system

PanaFlow HT

meets the requirements listed in the following standards:

- IEC 61508 part 1, part 2 and part 3: 2010, capable up to SIL 2 (HFT = 0) and SIL 3 (HFT ≥ 1)

Certification program Leittechnik (SEB-ZE-SEECERT-VA-320-20, Rev. 5.1 / 04.19)

Base of certification is the report
SEBS-A.102618/13TB in the valid version.

This certificate entitles the holder to use
the pictured safety approved mark.

Valid until: 2025-03-19
File reference: 8117998390

Hamburg, 2020-03-19


Bianca Pfuff

