

Certificate

SEBS-A.103402/15, V1.0

TÜV NORD Systems GmbH & Co. KG hereby certifies to

**Honeywell International Inc.
Honeywell Field Products**

512 Virginia Drive
Fort Washington, PA 19034, USA

that the safety-related

**SmartLine STT750 HART
Temperature Transmitter**

is capable for safety related applications up to SIL 2 / SIL 3, depending on the architecture and meets the requirements listed in the following standard.

IEC 61508: 2010; Functional safety of electrical/electronic/programmable electronic safety-related systems;
Capable up to SIL 2 for single transmitter use;
Capable up to SIL 3 for multiple transmitter use

Base of certification is the report SEBS-A.103402/15TB
in the valid version.

This certificate entitles the holder to use the pictured
safety approved mark.

Valid until: 2020-12-17

File reference: 8112717333

Hamburg, 2015-12-17



Bianca Pfuff

