

# Certificate

No. SEBS-A.093133/16 V 1.0

TÜV NORD Systems GmbH & Co. KG hereby certifies to

**GE Druck Limited**

Fir Tree Lane

Groby, Leicester LE6 0FH  
England

that the pressure transmitter

## PTX405 10k Generic SIL Sensor

(derived from drawing 117M8879) is capable for safety related applications up to SIL 2 (HFT = 0) and up to SIL 3 (HFT > 0) and meets the requirements listed in the following standards.

- IEC 61508 part 1, part 2 and part 3: 2010


Base of certification is the report  
SEBS-A.093133/16TB in the valid version.

This certificate entitles the holder to use the  
pictured safety approved mark.

Valid until: 2022-02-23

File reference: 8113928496

Hamburg, 2017-02-23



Bianca Pfuff

