

Certificate

No. SEBS-A.114623/17 V1.0

TÜV NORD Systems GmbH & Co. KG hereby certifies to

Dräger Safety AG & Co. KGaA

Revalstraße 1
23560 Lübeck
Germany

That the wireless gas measurement system

Polytron 6100 EC WL

meets the requirements listed in the below mentioned standards

- IEC 61508-1:2010; SIL 2; SC2
- IEC 61508-2:2010; SIL 2; SC2
- IEC 61508-3:2010; SIL 2; SC2

Certification program Leittechnik (SEB-ZE-SEECERT-VA-320-20, Rev. 5.1 / 04.19)

Base of certification is the report
No. SEBS-A.114623/17 TB in the valid
version.

This certificate entitles the holder to use
the pictured safety approved mark.

Expiry date: 14.04.2026
Reference No.: 8114270929

Hamburg, 14.04.2021


Bianca Pfuff

