

Certificate

No. SEBS-A.161422/17 V 1.0

TÜV NORD Systems GmbH & Co. KG hereby certifies to

JUMO GmbH & Co.KG

Moritz-Juchheim-Straße 1
36039 Fulda

that the safety related electromagnetic flowmeters

JUMO flowTRANS MAG

meet the relevant requirements listed in the following standards.

-
- DIN EN 61508-1/-2: 2011 capable up to SIL 2 in low demand applications
 - IEC 61508-1/-2: 2010 capable up to SIL 2 in low demand applications
-

The type-list of the products is pictured on the backside of this certificate.

The certification is based on the report
No. SEBS-A.161422/17TB in the valid
version.

This certificate entitles the holder to use
the pictured Safety Approved mark.

Expiry date: 2022-04-04

Reference No.: 8114373837

Hamburg, 2017-04-04



Bianca Pfuff



Product-Typelist for certificate SEBS-A.161422/17, V 1.0

Flowmeter Variant
JUMO flowTRANS MAG S01 406012/1-0
JUMO flowTRANS MAG H01 406015/1-0
JUMO flowTRANS MAG S02 406013/1-0
JUMO flowTRANS MAG H02 406016/1-0
JUMO flowTRANS MAG S01 406012/2-0 with Transmitter JUMO flowTRANS MAG 01 406018/2-0
JUMO flowTRANS MAG H01 406015/2-0 with Transmitter JUMO flowTRANS MAG 01 406018/2-0
JUMO flowTRANS MAG S02 406013/2-0 with Transmitter JUMO flowTRANS MAG 02 406019/2-0
JUMO flowTRANS MAG H02 406016/2-0 with Transmitter JUMO flowTRANS MAG 02 406019/2-0
JUMO flowTRANS MAG S01 406012/1-1
JUMO flowTRANS MAG H01 406015/1-1
JUMO flowTRANS MAG S02 406013/1-1
JUMO flowTRANS MAG H02 406016/1-1
JUMO flowTRANS MAG S01 406012/2-1 with Transmitter JUMO flowTRANS MAG 01 406018/2-1
JUMO flowTRANS MAG H01 406015/2-1 with Transmitter JUMO flowTRANS MAG 01 406018/2-1
JUMO flowTRANS MAG S02 406013/2-1 with Transmitter JUMO flowTRANS MAG 02 406019/2-1
JUMO flowTRANS MAG H02 406016/2-1 with Transmitter JUMO flowTRANS MAG 02 406019/2-1