

Certificate

No. SEBS-A.102152/17 V 1.0

TÜV NORD Systems GmbH & Co. KG hereby certifies to

GE Druck Limited

Fir Tree Lane

Groby, Leicester LE6 0FH

England

that the pressure transmitter

PTX405 10k SIL Sensor 12mA output at 430barA Variant

(derived from drawing 123M2534) is capable for safety related applications and meets the requirements listed in the following standards.

- IEC 61508 part 1, part 2 and part 3: 2010, SIL 2 with HFT = 0 and SIL 3 with HFT > 0

Certification program (SEB-ZE-SEECERT-VA-320-20, Rev. 3/9.15)


Base of certification is the report
SEBS-A.102152/17TB in the valid version.

This certificate entitles the holder to use the
pictured safety approved mark.

Valid until: 2023-02-22

File reference: 8114987810

Hamburg, 2018-02-22



Bianca Pfuff

