

Certificate

No. SEBS-A.122714/17, V1.0

TÜV NORD Systems GmbH & Co. KG hereby certifies to

**Honeywell International Inc.
Honeywell Field Products**

512 Virginia Drive
Fort Washington, PA 19034, USA

that the safety-related

SmartLine ST 800 HART Pressure Transmitter

is capable for safety related applications up to SIL 2 / SIL 3, depending on the architecture and meets the requirements listed in the following standard.

**IEC 61508: 2010; Functional safety of electrical/electronic/programmable electronic safety-related systems;
Capable up to SIL 2 for single transmitter use;
Capable up to SIL 3 for multiple transmitter use**

Certificationprogram Leittechnik (SEB-ZE-SEECERT-VA-320-20, Rev. 3/9.15)


Base of certification is the report
SEBS-A.122714/17TB in the valid
version.

This certificate entitles the holder to
use the pictured safety approved mark.

Valid until: 2023-03-28

File reference: 8115314554

Hamburg, 2018-03-28



Bianca Pfuff

