

# Certificate

No. SEBS-A.114857/17-1, V1.0

TÜV NORD Systems GmbH & Co. KG hereby certifies to

## NEWAY VALVE (SUZHOU) CO., LTD

No.666 Taishan Road, New District  
Suzhou 215129  
P.R.China

that the double/ triple offset

### Butterfly Valves

meets the requirements listed in the below mentioned standard

---

|                  |                                        |
|------------------|----------------------------------------|
| IEC 61508: 2010; | SIL 2 capability in 1oo1 configuration |
|                  | SIL 3 capability in 1oo2 configuration |

---

Base of certification is the decision report DE\_SEBS-A.114857/17 and the tracking list in the valid version.

This certificate entitles the holder to use the pictured safety approved mark.

Valid until: 2022-08-01  
File reference: 8114892160

Hamburg, 2017-08-01

  
Bianca Pfuff



**Butterfly Valves**

IEC 61508:2010 SIL2 in 1oo1  
IEC 61508:2010 SIL3 in 1oo2

SEBS-A.114857/17-1



# Tracking list of the Butterfly Valves Version 0.2



Certificate-Nr. SEBS-A114857/17-1, V 1.0

| Component                             | Ranges | Report Number         | File reference | Certification status | Date of certification | Expiry date |
|---------------------------------------|--------|-----------------------|----------------|----------------------|-----------------------|-------------|
| API 609 Double offset butterfly valve | 2"~48" | DE_SEBS-A.114857/17   | 8114892160     | valid                | 01-08-2017            | 01-08-2022  |
| API 609 Triple offset butterfly valve | 2"~48" | DE_SEBS-A.114857/17TB | 8114892160     | valid                | 01-08-2017            | 01-08-2022  |

|            | Release Neway: | Quality Assurance | Release Certification body: |
|------------|----------------|-------------------|-----------------------------|
| Signature: |                |                   |                             |
| Date:      |                | 1. 10. 2018       | 1. 10. 2018                 |

TUV NORD